

## **Board of Health Meeting**

**August 20, 2018**

**Present: Gerald Maher, Chairman, Tyler Nims, Vice-Chairman, Mark MacDonald, Clerk, Peter Falabella, Director of Public Health,**

**The Board of Health Meeting opened at 7:00 p.m.**

**7:00 57 Ireland Rd.** – The plan is for repair of an existing septic system, designed by Morse Engineering. Mr. Falabella described the plan, as Morse Engineering was unable to attend. A proposed HOOT H600 Treatment Tank, with a 1500 gallon pump chamber and Geo Flow drip dispersal field (26' x 36') was proposed. The I/A technology credits requested were for allowing only 2 ft. of permeable material, and allowing a 3 ft. separation to groundwater. Approximately 31"-36" of A/B horizon was found, with a C1 layer of Sandy loam and a C2 layer of silt loam. The C1 perc test was 84 mpi, and the engineer chose to use the A/B horizons instead. System location was in the rear yard. The BOH members agreed to allow the credits for this system 3-0.

The meeting concluded at 7:30 p.m.

Next meeting: October 22, 2018