

## **Board of Health Meeting**

**May 15, 2017**

**Present: Gerald Maher, Chairman, Tyler Nims, Vice-Chairman, Mark MacDonald, Clerk, Peter Falabella, Director of Public Health.**

**The Board of Health Meeting opened at 7:00 p.m.**

**7:00 178 Highland St., Bob Crawford, EET presenting.** This plan of repair is for a 4 bedroom existing home with a failed system. The entire lot is surrounded by wetlands, leaving few options for placement of the system. A 1500 gallon septic tank, 1000 gallon pump chamber and a Presby Enviro Septic system is proposed. The local upgrades requested include (a) Reduction in groundwater separation from 5' to 4', and (b) Sieve test performed in lieu of a perc test. The local variances requested included the reduction in distance from the wetlands to the Septic Tank at 35' and Pump Chamber at 51'. The BOH voted to approve 3-0.

**7:10 169 Main St. – Jeff Hassett, Morse Engineering presenting.** The plan is for repair of a failed cesspool under the deck at the house. Soil tests demonstrated Loamy sands, with high groundwater at 6.9'. The local upgrades requested include (a) a Reduction in the groundwater separation distance from 5' to 4', and (b) Reduction in distance from the property line to the Septic System at 6' and at 7.8' The abutters were notified. The BOH approved 3-0.

**7:20 Body Art Practitioner License – Susan Jackson** appeared to request a license as a Body Art Practitioner at 1028 Ocean St. (Eye Candy), specifically for microblading practice. Ms. Jackson discussed her experience in Weymouth and Norwell and her background and qualifications. After some discussion, the BOH voted to grant a Body Art Practitioner license to Susan Jackson for the practice of microblading at 1028 Ocean St., after receipt of her current First Aid certification.

The meeting concluded at 8:00 p.m.