



MARSHFIELD FIRE DEPARTMENT
60 South River Street
Marshfield, Massachusetts 02050-4545

Received

MAR 5 2020

Marshfield Planning Dept.

Telephone: 781-837-1315
Fax: 781-834-5579

William Hocking
Chief of Department

Administration: 781-834-5546
e-mail: admin@marshfieldfire.org

Thomas Corbo
Deputy Chief

3/4/2020

Dear planning board members,

I have reviewed the site plans forwarded to me by Atlantic design engineers regarding the three parking canopies to be erected at the fair ground property.

The requirements that I want put forward, and that Atlantic design engineers have agreed to, would be to have a minimum vertical clearance of thirteen feet and that the driving aisle be a minimum of twenty four feet in width. Furthermore, there is no requirement for any fire suppression to be installed into this project.

Although I have the right to review any additional details during the permit process, I have no reservations of this project moving forward.

Thank you,

Deputy Thomas Corbo

From: Brendon Reali <breali@atlanticcompanies.com>
Sent: Thursday, March 5, 2020 4:09 PM
To: Guimond, Greg
Cc: Ramsey, Kay; 'Chris King'; Asa Smith; 'Jeremy Karpf' Marshfield Planning Dept.
Subject: 33 S. River St - Marshfield Fairgrounds Solar Carport - Fire Department Review Letter
Attachments: Fire Department Review 3-2-20.pdf

Greg,

Per comments made by the Marshfield Planning Board during the February 24, 2020, public hearing for the proposed Solar Carport Project at 33 South River Street, Atlantic Design Engineers has obtained a review letter from the Marshfield Fire Department (See attached).

The letter indicates Deputy Thomas Corbo reviewed a copy of the site plans. Accordingly, the carport array was designed to have a minimum vertical clearance of 13 feet and a minimum drive aisle width of 24 feet. Furthermore, Deputy Corbo indicated there is no requirement for fire suppression to be installed as part of this project.

Please feel free to contact me or our project manager Chris King with any questions.

Thanks,

Brendon Reali
Environmental Scientist
Renewables & Environmental Science
 **Atlantic Design Engineers, Inc.**

1 (508) 888-9282 ext. 28
www.atlanticcompanies.com
[Facebook](#) | [LinkedIn](#) | [Google Plus](#)

For sending larger files to Atlantic use:
[Atlantic's Upload Utility via Hightail](#)